## **COMPRESSOR DATA SHEET**



## Federal Uniform Test Method for Certain Air Compressors Not Applicable

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer:	Gardr	er Denver					
	Model Number	ETSV	225-300hp-200p	osi	Date:	02/07/24		
2	Air-co	Air-cooled X Water-cooled			Type:	Screw		
	X Lubric	ated	Oil Free		# of Stages:	1		
3*	Full Load Operating Pressure <sup>b</sup>			125	psig b			
4	Drive Motor No	Drive Motor Nominal Rating			hp			
5	Drive Motor No	Drive Motor Nominal Efficiency			percent			
6	Fan Motor Non	Fan Motor Nominal Rating (if applicable)			hp			
7	Fan Motor Non	ninal Efficier	ncy	NA	percent			
8*	Input Power (kW)			Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>			
	283.05			1546.2		18.31		
	238.52			1326.8		17.98		
	193.61			1096.9	17.65			
	151.67			861.6		17.60		
	110.64			622.1		17.78		
	69.42			371.0		18.71		
9*	Total Package Input Power at Zero Flow c, d			20.5	kW			
10	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00 15.00 10.00 0.0	200.0 400.0  Note: Graph is only lote: Y-Axis Scale, 10 to			1600.0 1800.0		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- $b.\ The\ operating\ pressure\ at\ which\ the\ Capacity\ (Item\ 8)\ and\ Electrical\ Consumption\ (Item\ 8)\ were\ measured\ for\ this\ data\ sheet.$
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

  NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	<u>ft<sup>3</sup> / min</u>	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: ETSV150-225A