COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR									
1	Manufacturer:	Gardn	er Denver						
	Model Number: ETSV225-300hp-200psi						Date:		02/07/24
2	X Air-coo	oled	Water-coole	d			Type:		Screw
				# of Stages:		1			
3*	Full Load Operating Pressure b				20	00	b psig		
4	Drive Motor Nominal Rating				30	00	hp		
5	Drive Motor Nominal Efficiency				95	.8	percent		
6	Fan Motor Nominal Rating (if applicable))	7.	5	hp		
7	Fan Motor Nominal Efficiency				86	.5	percent		
8*	Input Power (kW)				Capacity (acfm) ^{a,d}		Specific Power (kW/100 acfm) ^d		
	284.66			122	3.5				
	241.75				104	7.1	23.09		
	197.05				861	1.9	22.86		
	156.34			673	3.9	23.20			
	116.68				483	3.3	24.14		
	93.75				369	9.0	25.41		
9*	Total Package Input Power at Zero Flow c, d			c, d	25	.3	kW		
10	Isentropic Effici	Isentropic Efficiency			82.	19	%		
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00 10.00 0.0	ote: Y-Axis Scale,	only a visua 10 to 35, + 3	600.0 apacity (ACFM) al representation 5kW/100acfm into 0 25% over maximal	crements if nece		1200.0	1400.0

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Configurator: ETSV150-225A